

DECLARATION OF PERFORMANCE

Nr. 2014/1 in accordance with Regulation (EU) No. 305/2011 (Construction Products Regulation CPR) Annex III

Fire stop collar RORCOL

1. Unique identification code of the product-type:

Fire stop collar RORCOL V30, RORCOL V60, RORCOL AV60,
gap filler BFM/K310

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):

Type designation: to be found on the label of the product

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

Penetration seals for burnable pipes,
not burnable pipes and
cables through walls and ceilings, according to ETA-13/0758

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

Air Fire Tech Brandschutzsysteme GmbH, Stranzenberggasse 7b/2, 1130 Wien, AUSTRIA

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2): n.a.

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V: System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:
n.a.

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

The Österreichisches Institut für Bautechnik has issued the European technical approval ETA-13/0758 according to the ETAG No. 026-part 2. The notified body MA39 - certification body – WIEN-ZERT performs the inspection according to Annex V System 1 and has issued the EC certificate of conformity 1139-CPD-0523/13.

9. Declared performance

Essential performance	Performance	Harmonised technical specification
Reaction to fire	Class E	EN 13501-1
Fire resistance	According to ETA-13/0758	EN 13501-2
Durability and Utilizability	Use category Y ₁	EOTA technical report TR 024
Dangerous substances	None	Council Directive 67/548/EEC and Regulation (EC) no 1272/2008

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Wien, January 2014



Air Fire Tech Brandschutzsysteme GmbH
A-1130 Wien, Stranzenberggasse 7b/2
T: 982 01 74-0, E: office@airfiretech.at

(Uwe Stefani,
CEO Air Fire Tech Brandschutzsysteme GmbH)

Air Fire Tech
Brandschutzsysteme GmbH
Stranzenberggasse 7b/2
A-1130 Wien

T: +43 1 982 01 74-0
F: +43 1 982 01 74-930
E: office@airfiretech.at
I: www.airfiretech.at

FN 267921b
UID: ATU 62003245
Gerichtsstand: HG Wien
Geschäftsführer: Uwe Stefani

ARA: 17431
UniCredit Bank Austria
IBAN: AT34 1200 0518 7228 4101
BIC: BKAUATWW